

**LAMPIRAN II**  
**KEPUTUSAN MENTERI PERTAMBANGAN DAN ENERGI**  
**NOMOR 300.K/38/M.pe/1997**  
**TENTANG**  
**KESELAMATAN KERJA PIPA PENYALUR MINYAK DAN GAS BUMI**

**JARAK MINIMUM PIPA PENYALUR**

KONSTRUKSI DIAMETER PIPA		JARAK MINIMUM (METER)		
INCI	MM	TEKANAN 4 s.d 16 BAR	TEKANAN ≥ 16 s.d 50 BAR	TEKANAN ≥ 50 s.d 100 BAR
2		2	-	-
4		2	-	-
6		2	-	-
8		2	3	3
10		2	3	3,5
12		-	3,5	4
14		-	4	4,5
16		-	4	4,5
18		-	4,5	5
20		-	4,5	5
22		-	4,5	5
24		-	4,5	5
28		-	5	6
30		-	5	6
36		-	6	7
42		-	7	7,5
48		-	7	7,5

MENTERI PERTAMRANGAN DAN ENERGI

ttd.

I.B. SUDJANA

Catatan:

1 inci = 25,4 mm

1 bar = 1,04 atm